

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1130:172 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Honeywell Inc., 1500 W. Dundee Rd., Arlington Heights, IL 60004-1472
Contact: Bob Hodgson (847) 797-4403

DESIGN: Models XLS403-3A, XLS403-5A, XLS403-7A and XLS403-8A adapter plate strobe lights. Unit may be followed by A through Z to specify market and suffix -B, -R or -W to indicate product color. It is designed to allow an add-on of separately listed GS Building Systems' Model 439 Series Bell (CSFM Listing No. 7135-1388:110). Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:

Candela:	-5A: 15cd
	-3A: 30cd
	-7A: 15/75cd
	-8A: 110cd
Electrical:	20-24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, candela/electrical rating and UL label.

APPROVAL: Listed as strobe lights suitable for the hearing impaired when used in conjunction with separately listed electrically and functionally compatible fire alarm control units. For indoor use only.

XLF: 7125-1388:209

09-12-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 13, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager